




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

| | | | |
|-------------------|-----------------------|----------|--------|
| Client: | Boom Interior | | |
| Object: | Xrozz Absorption Plus | | |
| Size [mm]: | w = 800 | h = 1800 | d = 50 |

| Octave band (Hz) | Equivalent sound absorption area / unit (m ² Sabine) |
|-----------------------------|---|
| 63 | 0.37 |
| 125 | 0.53 |
| 250 | 1.2 |
| 500 | 1.8 |
| 1000 | 2.4 |
| 2000 | 2.6 |
| 4000 | 2.8 |
| N₁₀ = 5.6 | |



| | |
|-----------------------------------|-----------------------|
| ORIGINAL TEST REPORT | DATE OF REPORT |
| Akustikverkstan report 21-720-M13 | 2021-06-23 |

