




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Boom Interior		
Object:	Xrozz Absorption Plus		
Size [mm]:	w = 800	h = 1800	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.37
125	0.53
250	1.2
500	1.8
1000	2.4
2000	2.6
4000	2.8
N₁₀ = 5.6	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 21-720-M13	2021-06-23

