




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Boom Interior		
Object:	Xrozz Floorscreen		
Size [mm]:	w = 800	h = 1200	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.3
125	0.4
250	0.7
500	0.9
1000	1
2000	1.2
4000	1.5
N₁₀ = 11.1	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 18-701-M7	2018-08-23

