




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Boom Interior		
Object:	Xrozz Floorscreen		
Size [mm]:	w = 1000	h = 1400	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.45
125	0.9
250	0.96
500	1.02
1000	1.44
2000	1.77
4000	2.14
N₁₀ = 9.8	



ORIGINAL TEST REPORTS	DATE OF REPORT
Akustikverkstan report 18-701-M9	2018-08-23
Akustikverkstan report 18-701-M10	2018-08-23

The presented results are interpolated using the method described in ISO 20189 from the original test reports.

