




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Boom Interior		
Object:	Xrozz Floorscreen		
Size [mm]:	w = 1200	h = 1400	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.6
125	0.6
250	1.1
500	1.4
1000	1.7
2000	2.1
4000	2.4
N₁₀ = 7.1	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 18-701-M11	2018-08-23

