


SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Boom Interior		
Object:	Xrozz Floorscreen		
Size [mm]:	w = 1400	h = 1400	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.6
125	0.7
250	1.2
500	1.6
1000	2
2000	2.4
4000	2.8
N₁₀ = 6.3	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 18-701-M12	2018-08-23

