




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Boom Interior		
Object:	Xrozz Floorscreen		
Size [mm]:	w = 1600	h = 1600	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.8
125	1
250	1.5
500	2.1
1000	2.6
2000	3.1
4000	3.6
N₁₀ = 4.8	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 18-701-M13	2018-08-23

