




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Boom Interior		
Object:	Xrozz Floorscreen		
Size [mm]:	w = 800	h = 1800	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.5
125	0.6
250	1
500	1.3
1000	1.5
2000	1.8
4000	2.2
N₁₀ = 7.7	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 18-701-M10	2018-08-23

