




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Blå Station		
Object:	Ginkgo		
Size [mm]:	w = 500	h = 420	d = 60

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.01
125	0.02
250	0.08
500	0.11
1000	0.1
2000	0.09
4000	0.09
N₁₀ = 111.1	



ORIGINAL TEST REPORT	DATE OF TEST
Akustikverkstan report 14-117-R1	2015-06-08

