




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

| | | | |
|-------------------|---------------|---------|---------|
| Client: | Abstracta | | |
| Object: | Moon lighting | | |
| Size [mm]: | w = 525 | h = 525 | d = 550 |

| Octave band (Hz) | Equivalent sound absorption area / unit (m ² Sabine) |
|------------------------------|---|
| 63 | |
| 125 | 0.27 |
| 250 | 0.51 |
| 500 | 0.61 |
| 1000 | 0.68 |
| 2000 | 0.76 |
| 4000 | 0.88 |
| N₁₀ = 16.4 | |



| | |
|-----------------------------|-----------------------|
| ORIGINAL TEST REPORT | DATE OF REPORT |
| KTH report 20230127.1 | 2023-01-27 |

