




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Götessons/ Gotessons, Akustikmiljö / Am Acoustics		
Object:	PlainPanel with EcoSund (2 groups of 6 pcs)		
Size [mm]:	w = 58	h = 58	d = 7

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.09
125	0.34
250	0.99
500	1.6
1000	2
2000	2.1
4000	2
N₁₀ = 6.3	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 2633-R1-M1	2023-03-08

