




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Abstracta Agile		
Size [mm]:	w = 1945	h = 1359	d = 540

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	1
250	1.7
500	1.9
1000	1.6
2000	1.5
4000	1.3
N₁₀ = 7.7	



ORIGINAL TEST REPORT	DATE OF REPORT
20220105.3	2023-04-21

