




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Abstracta		
<b>Object:</b>	dB Modular Sofa		
<b>Size [mm]:</b>	w = 1500	h = 860	d = 620

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0
125	1.9
250	2.6
500	3.1
1000	3.8
2000	4
4000	3.9
<b>N<sub>10</sub> = 3.2</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
20210127.2	2023-05-02

