




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	dB Modular Sofa		
Size [mm]:	w = 1500	h = 860	d = 620

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	1.9
250	2.6
500	3.1
1000	3.8
2000	4
4000	3.9
N₁₀ = 3.2	



ORIGINAL TEST REPORT	DATE OF REPORT
20210127.2	2023-05-02

