




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Softline 40		
Size [mm]:	w = 1600	h = 650	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0.31
250	0.75
500	0.98
1000	1.17
2000	1.3
4000	1.54
N₁₀ = 10.2	



ORIGINAL TEST REPORT	DATE OF REPORT
20210118.2	2023-05-03

