




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Holly lighting, horizontal		
Size [mm]:	w = 1052	h = 585	d = 540

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0.23
250	0.77
500	1.09
1000	0.92
2000	0.99
4000	1.05
N₁₀ = 10.9	



ORIGINAL TEST REPORT	DATE OF REPORT
20220608.1	2023-04-20

