




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Holly lighting, vertical (corner position)		
Size [mm]:	w = 883	h = 585	d = 540

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0.42
250	0.64
500	0.84
1000	0.67
2000	0.73
4000	0.82
N₁₀ = 14.9	



ORIGINAL TEST REPORT	DATE OF REPORT
20220608.1	2023-04-20

