




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Scala XL (concave upholstered with fabric)		
Size [mm]:	w = 1183	h = 2300	d = 90

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0.36
250	1.1
500	2.18
1000	2.88
2000	3.14
4000	3.68
N₁₀ = 4.6	



ORIGINAL TEST REPORT	DATE OF REPORT
20210128.2	2023-04-21

