




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta
Object:	Scala XL (convex upholstered with fabric)
Size [mm]:	w = 1183 h = 2300 d = 90

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0.7
250	1.46
500	2.47
1000	2.74
2000	2.98
4000	3.64
N₁₀ = 4	



ORIGINAL TEST REPORT	DATE OF REPORT
20210128.2	2023-04-21

