




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Basic Baffle		
Size [mm]:	w = 1200	h = 650	d = 30

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0.5
250	0.8
500	1
1000	1.4
2000	1.6
4000	1.8
N ₁₀ = 10	



ORIGINAL TEST REPORT	DATE OF REPORT
20210128.3	2023-05-09

