




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Basic Baffle (Parallel, 25 cm distance in between)		
Size [mm]:	w = 1200	h = 650	d = 30

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0.3
250	0.4
500	0.6
1000	0.8
2000	0.9
4000	0.8
N ₁₀ = 16.7	



ORIGINAL TEST REPORT

20210128.3

DATE OF REPORT

2023-05-09

