




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

**Client:** Abstracta  
**Object:** Basic Baffle (Parallel, 25 cm distance in between)  
**Size [mm]:** w = 1200      h = 650      d = 30

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0
125	0.3
250	0.4
500	0.6
1000	0.8
2000	0.9
4000	0.8
N <sub>10</sub> = 16.7	



ORIGINAL TEST REPORT

20210128.3

DATE OF REPORT

2023-05-09

