




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Abstracta		
<b>Object:</b>	Basic Baffle (Parallel, 25 cm distance in between)		
<b>Size [mm]:</b>	w = 1200	h = 650	d = 30

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0
125	0.3
250	0.4
500	0.6
1000	0.8
2000	0.9
4000	0.8
<b>N<sub>10</sub> = 16.7</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
20210128.3	2023-05-09

