


SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Basic Baffle		
Size [mm]:	w = 2000	h = 650	d = 30

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0.9
250	1.2
500	1.6
1000	2.2
2000	2.5
4000	2.8
N₁₀ = 6.3	



ORIGINAL TEST REPORT	DATE OF REPORT
20210128.3	2023-05-09

