




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Basic Baffle (Parallel, 25 cm distance in between)		
Size [mm]:	w = 2000	h = 650	d = 30

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0.49
250	0.7
500	1.03
1000	1.36
2000	1.51
4000	1.34
N₁₀ = 9.7	



ORIGINAL TEST REPORT	DATE OF REPORT
20210128.3	2023-05-09

