




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Abstracta		
<b>Object:</b>	Bits Wall XL		
<b>Size [mm]:</b>	w = 748	h = 649	d = 100

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0
125	0.08
250	0.15
500	0.24
1000	0.28
2000	0.26
4000	0.23
<b>N<sub>10</sub> = 43.5</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
20200828.2	2023-05-10

