




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Abstracta		
<b>Object:</b>	Abstracta x Wall of Art		
<b>Size [mm]:</b>	w = 1400	h = 1000	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	
125	0.4
250	0.7
500	1.3
1000	0.9
2000	0.7
4000	0.6
<b>N<sub>10</sub> = 16.7</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
20230605.1	2023-08-14

