




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Akunok Sofa 1 Seater		
Size [mm]:	w = 1090	h = 1290	d = 980

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	
125	2.2
250	3
500	3.9
1000	4.2
2000	4.3
4000	3.7
N₁₀ = 2.7	



ORIGINAL TEST REPORT	DATE OF REPORT
20231213.3	2023-12-18

