




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Abstracta		
<b>Object:</b>	Vika lamp		
<b>Size [mm]:</b>	w = 1500	h = 155	d = 283

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	
125	0.04
250	0.24
500	0.52
1000	0.7
2000	0.91
4000	0.8
<b>N<sub>10</sub> = 19.2</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
20231213.8	2023-12-18

