




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Vika lamp		
Size [mm]:	w = 1500	h = 155	d = 283

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	
125	0.04
250	0.24
500	0.52
1000	0.7
2000	0.91
4000	0.8
N₁₀ = 19.2	



ORIGINAL TEST REPORT	DATE OF REPORT
20231213.8	2023-12-18

