




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Vika Floor Screen 3		
Size [mm]:	w = 1180	h = 1540	d = 231

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	
125	0.5
250	1.2
500	2.6
1000	3.1
2000	3.4
4000	3.4
N₁₀ = 3.8	



ORIGINAL TEST REPORT	DATE OF REPORT
20231213.9	2023-12-18

