




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	OFFECCT		
Object:	Membrane		
Size [mm]:	w = 1405	h = 1614	d = 100

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0.1
250	0.2
500	0.5
1000	1.1
2000	1.5
4000	1.6
N ₁₀ = 20	



ORIGINAL TEST REPORT	DATE OF TEST
Akustikverkstan report 15-226-M7	2015-11-11

