




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	OFFECCT		
<b>Object:</b>	Soundwave Pix 24 pcs.		
<b>Size [mm]:</b>	w = 1755	h = 1170	d = 57

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.1
125	0.4
250	1.6
500	1.5
1000	1.4
2000	1.4
4000	1.4
<b>N<sub>10</sub> = 7.1</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF TEST</b>
Akustikverkstan report 14-41-M22	2014-06-04

