




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	OFFECCT		
Object:	Soundwave Pix 24 pcs.		
Size [mm]:	w = 1755	h = 1170	d = 57

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.1
125	0.4
250	1.6
500	1.5
1000	1.4
2000	1.4
4000	1.4
N₁₀ = 7.1	



ORIGINAL TEST REPORT	DATE OF TEST
Akustikverkstan report 14-41-M22	2014-06-04

