




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Softline		
Size [mm]:	w = 1000	h = 1700	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.2
125	0.7
250	1.5
500	2.6
1000	3.1
2000	3.1
4000	3.1
N₁₀ = 3.8	



ORIGINAL TEST REPORT	DATE OF TEST
P504551-B	2013-06-05

