




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Alumi		
Size [mm]:	w = 1206	h = 1506	d = 63

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.4
125	0.9
250	2
500	2.7
1000	2.9
2000	2.9
4000	2.9
N₁₀ = 3.7	



ORIGINAL TEST REPORT	DATE OF TEST
SP report PX04109BE	2013-06-14

