




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Abstracta		
<b>Object:</b>	Alumi		
<b>Size [mm]:</b>	w = 1206	h = 1506	d = 63

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.4
125	0.9
250	2
500	2.7
1000	2.9
2000	2.9
4000	2.9
<b>N<sub>10</sub> = 3.7</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF TEST</b>
SP report PX04109BE	2013-06-14

