




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Airflake Line Closed		
Size [mm]:	w = 2000	h = 720	d = 20

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0
250	0.1
500	0.7
1000	1
2000	0.8
4000	0.9
N ₁₀ = 14.3	



ORIGINAL TEST REPORT

DATE OF TEST

SP report P702033-E

2013-08-12

