




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Airflake Blade Open		
Size [mm]:	w = 2000	h = 720	d = 20

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0
250	0
500	0.1
1000	0.4
2000	0.5
4000	0.6
N₁₀ = 100	



ORIGINAL TEST REPORT	DATE OF TEST
SP report P702033-E	2013-08-12

