




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Glimakra Of Sweden		
<b>Object:</b>	Alp Large		
<b>Size [mm]:</b>	w = 1180	h = 1800	d = 461

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0
125	0.3
250	0.8
500	1.8
1000	3.4
2000	3.9
4000	4.1
<b>N<sub>10</sub> = 5.6</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF TEST</b>
WSP Acoustics report 10171560.01	2012-01-30

