




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Kinnarps		
Object:	Oktav 96 6pcs		
Size [mm]:	w = 1650	h = 1100	d = 96

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.1
125	0.4
250	1.1
500	1.8
1000	2
2000	1.9
4000	1.9
N₁₀ = 5.6	



ORIGINAL TEST REPORT	DATE OF TEST
SP report PX18419	2012-01-12

