




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Kinnarps		
<b>Object:</b>	Oktav 60 6pcs		
<b>Size [mm]:</b>	w = 1650	h = 1100	d = 60

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.1
125	0.3
250	0.8
500	1.5
1000	1.9
2000	1.9
4000	1.8
<b>N<sub>10</sub> = 6.7</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF TEST</b>
SP report PX18419	2012-01-12

