




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Kinnarps		
Object:	Oktav 60 6pcs		
Size [mm]:	w = 1650	h = 1100	d = 60

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.1
125	0.3
250	0.8
500	1.5
1000	1.9
2000	1.9
4000	1.8
N₁₀ = 6.7	



ORIGINAL TEST REPORT	DATE OF TEST
SP report PX18419	2012-01-12

