




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Kinnarps		
Object:	Rezon with EPP		
Size [mm]:	w = 960	h = 1720	d = 30

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0.5
250	0.33
500	0.33
1000	0.5
2000	0.5
4000	0.66
N₁₀ = 30.3	



ORIGINAL TEST REPORT	DATE OF TEST
SP report P700972-CE	2013-06-05

