




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Blå Station		
<b>Object:</b>	Gaia 8 pcs		
<b>Size [mm]:</b>	w = 2600	h = 1300	d = 90

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.1
125	0.2
250	1
500	2.3
1000	2.8
2000	2.9
4000	3
<b>N<sub>10</sub> = 4.3</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan report 16-165-M6	2016-09-23

