




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	OFFECCT		
<b>Object:</b>	Float High Large Sofa		
<b>Size [mm]:</b>	w = 2120	h = 1300	d = 900

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	2
125	3.2
250	3.9
500	4.7
1000	5.8
2000	7.4
4000	8.6
<b>N<sub>10</sub> = 2.1</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF TEST</b>
Akustikverkstan report 13-99-R1	2013-09-03

