




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	OFFECCT
<b>Object:</b>	Soundwave® Botanic 6 pcs.
<b>Size [mm]:</b>	w = 1755      h = 1170      d = 62

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.1
125	0.4
250	1
500	1.6
1000	2.1
2000	2
4000	1.9
<b>N<sub>10</sub> = 6.3</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF TEST</b>
Akustikverkstan report 13-99-R1	2013-09-03

