




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	OFFECCT
<b>Object:</b>	Soundwave® Scrunch 6 pcs.
<b>Size [mm]:</b>	w = 1755      h = 1170      d = 60

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0
125	0.2
250	0.6
500	1.4
1000	1.8
2000	2.1
4000	2.1
<b>N<sub>10</sub> = 7.1</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF TEST</b>
Akustikverkstan report 13-99-R1	2013-09-03

