




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	OFFECCT		
Object:	Soundwave® Flo 6 pcs.		
Size [mm]:	w = 1755	h = 1170	d = 60

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.1
125	0.3
250	0.7
500	1.5
1000	2.2
2000	2.3
4000	2.1
N₁₀ = 6.7	



ORIGINAL TEST REPORT	DATE OF TEST
Akustikverkstan report 13-99-R1	2013-09-03

