




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	OFFECCT
<b>Object:</b>	Soundwave® Luna 6 pcs.
<b>Size [mm]:</b>	w = 1750      h = 1170      d = 80

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.2
125	0.7
250	1.3
500	2.2
1000	2.5
2000	2.5
4000	2.4
<b>N<sub>10</sub> = 4.5</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF TEST</b>
Akustikverkstan report 13-99-R1	2013-09-03

